

viewed on the Commission’s Web site at <http://www.ferc.gov> using the “eLibrary” link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at FERCOOnlineSupport. A copy of the application is also available for inspection and reproduction at the address in item h above.

Register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, .211, and .214. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission’s Rules may become a party to the proceeding. Any comments, protests, or motions to intervene must be received on or before the specified comment date for the particular application.

All filings must (1) bear in all capital letters the title “PROTEST”, “MOTION TO INTERVENE”, “COMMENTS,” “REPLY COMMENTS,” “RECOMMENDATIONS,” “TERMS AND CONDITIONS,” or “PRESCRIPTIONS;” (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. All comments, recommendations, terms and conditions or prescriptions must set forth their evidentiary basis and otherwise comply with the requirements of 18 CFR 4.34(b). Agencies may obtain copies of the application directly from the applicant. A copy of any protest or motion to intervene must be served

upon each representative of the applicant specified in the particular application. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

o. Procedural Schedule:

The application will be processed according to the following revised Hydro Licensing Schedule. Revisions to the schedule may be made as appropriate.

Milestone	Target Date
Filing of recommendations terms and conditions, and prescriptions.	August 2015.
Commission issues Environmental Assessment.	February 2016.

p. Final amendments to the application must be filed with the Commission no later than 30 days from the issuance date of this notice.

q. A license applicant must file no later than 60 days following the date of issuance of the notice of acceptance and ready for environmental analysis provided for in 5.22: (1) A copy of the water quality certification; (2) a copy of the request for certification, including proof of the date on which the certifying agency received the request; or (3) evidence of waiver of water quality certification.

Dated: June 12, 2015.

Kimberly D. Bose,

Secretary.

[FR Doc. 2015-15097 Filed 6-18-15; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CD15-26-000]

Mountain Village, CO; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On June 3, 2015, the town of Mountain Village, CO filed a notice of intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act (FPA), as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The proposed San Joaquin PRV Hydro Project would have an installed capacity of 15 kilowatts (kW) and would be located on the existing water supply pipeline for Mountain Village, which transports water for municipal consumption. The project would be located near Mountain Village in San Miguel County, Colorado.

Applicant Contact: Finn Kjome, Director of Public Works, 455 Mountain Village Blvd., Suite A, Mountain Village, CO 81435, Phone No. (970) 369-8206.

FERC Contact: Robert Bell, Phone No. (202) 502-6062, email: robert.bell@ferc.gov.

Qualifying Conduit Hydropower Facility Description: The proposed project would consist of: (1) A proposed short, 2-inch-diameter intake pipe that connects to a 10-inch-diameter main water supply pipe; (2) a proposed powerhouse that contains one turbine-generator unit with an installed capacity of 15 kW; (3) a proposed short 2-inch-diameter exit pipe returning flow to the main water supply pipe, making the total bypass approximately 10-feet; and (5) appurtenant facilities. The proposed project would have an estimated annual generating capacity of 15 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or deemed to meet all of the criteria shown in the table below.

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A), as amended by HREA ...	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar manmade water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity.	Y
FPA 30(a)(3)(C)(i), as amended by HREA	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY—Continued

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(C)(ii), as amended by HREA FPA 30(a)(3)(C)(iii), as amended by HREA.	The facility has an installed capacity that does not exceed 5 megawatts On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y Y

Preliminary Determination: Based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility, which is not required to be licensed or exempted from licensing.

Comments and Motions to Intervene: Deadline for filing comments contesting whether the facility meets the qualifying criteria is 45 days from the issuance date of this notice.

Deadline for filing motions to intervene is 30 days from the issuance date of this notice.

Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

Filing and Service of Responsive Documents: All filings must (1) bear in all capital letters the “COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY” or “MOTION TO INTERVENE,” as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission’s regulations.¹ All comments contesting Commission staff’s preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the Commission’s eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end

of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

Locations of Notice of Intent: Copies of the notice of intent can be obtained directly from the applicant or such copies can be viewed and reproduced at the Commission in its Public Reference Room, Room 2A, 888 First Street NE., Washington, DC 20426. The filing may also be viewed on the web at <http://www.ferc.gov/docs-filing/elibrary.asp> using the “eLibrary” link. Enter the docket number (e.g., CD15-26-000) in the docket number field to access the document. For assistance, call toll-free 1-866-208-3676 or email FERCOnlineSupport@ferc.gov. For TTY, call (202) 502-8659.

Dated: June 15, 2015.
Kimberly D. Bose,
Secretary.
[FR Doc. 2015-15098 Filed 6-18-15; 8:45 am]
BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CD15-27-000]

Mountain Village, CO; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On June 3, 2015, the town of Mountain Village, CO filed a notice of

intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act (FPA), as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The proposed Double Cabins PRV Hydro Project would have an installed capacity of 5 kilowatts (kW) and would be located on the existing water supply pipeline for Mountain Village, which transports water for municipal consumption. The project would be located near Mountain Village in San Miguel County, Colorado.

Applicant Contact: Finn Kjome, Director of Public Works, 455 Mountain Village Blvd., Suite A, Mountain Village, CO 81435, Phone No. (970) 369-8206.

FERC Contact: Robert Bell, Phone No. (202) 502-6062, email: robert.bell@ferc.gov.

Qualifying Conduit Hydropower Facility Description: The proposed project would consist of: (1) A proposed short, 2-inch-diameter intake pipe that connects to a 10-inch-diameter main water supply pipe; (2) a proposed powerhouse that contains one turbine-generator unit with an installed capacity of 5 kW; (3) a proposed short 2-inch-diameter exit pipe returning flow to the main water supply pipe, making the total bypass approximately 10-feet; and (5) appurtenant facilities. The proposed project would have an estimated annual generating capacity of 10 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or deemed to meet all of the criteria shown in the table below.

¹ 18 CFR 385.2001-2005 (2014).